

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 2280-2112:0100 Page 1 of 1

CATEGORY: 2280 -- COATING MATERIALS (FLAME SPREAD)

LISTEE: FIREFREE COATINGS, INC 580 Irwin Steet, Suite 1, San Rafael, CA 94901
Contact: Elisa Vivas (415) 459-6488 Ext: 11 Fax (415) 459-6055
Email: evivas@firefree.com

DESIGN: Firefree Class A Coating on OSB with nominal 6 mils dry film thickness. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class A on OSB

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product label and SFM label.

APPROVAL: Listed as a coating material for application to OSB to reduce flame spread. Approval limited to interior wall/ceiling surfaces when the coatings are applied at the rates specified in accordance with the manufacturer's installation instructions to a 6 mils dry film thickness. Authority having jurisdiction should be consulted prior to installation.

10-22-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division